WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20977
Permit No.
Basin

1. OWNER Richard Salisbury ADDRESS 19990 Cold Springs Dr.

2. LOCATION SW ¼ SW ¼ Sec. 20 T. 21 N N/S R. 18 E W/ASHOE County
PERMIT NO. 1078

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSAND		0	3	3
Fine Sand w/Brn. Clay		3	53	50
Gravels to 3/4" well				
Rounded, with Fine		53	150+	97
Multi Col Sands				

Date started 4-14, 1980
Date completed 4-15, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew at 170# for 1 hr to			
Clean & Develop			
—Approx 12 gpm—			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4 to 56 8 3/4 to T.D. inches Total depth 150 feet
Casing record 6 5/8 OD
Weight per foot Thickness .156

Diameter	From	To
6 5/8 OD inches	+2 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 56' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 56 feet to 150 feet

Perforations:
Type perforation Jackey
Size perforation 1/8 x 3
From 130 feet to 150 feet
From 90 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 70 Feet below land surface
Flow G.P.M. 12
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service
Address 2255 Glendale Ave. Sparks
Nevada contractor's license number 15291
Nevada driller's license number 1037
Signed [signature]
Date 4-15-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627