WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20981
Permit No.
Basin

1. OWNER Frank Steinheimer ADDRESS 4030 Jasper LA. Reno

2. LOCATION SE ¼ NW ¼ Sec. 25 T. 19 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Hot Water
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	8	8
clay sand		8	24	16
sand		24	37	13
clay		37	64	27
sand clay		64	71	7
sand		71	76	5
clay		76	97	21
Blue clay		97	112	15
clay		112	115	3
Blue clay		115	122	3
clay		122	145	23
sand clay		145	160	15
Blue clay		160	171	11
sand clay		171	188	17
Blue clay		188	228	40
sand clay		228	260	32

Date started 4-9, 1980
Date completed 4-16, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 260 feet
Casing record
Weight per foot Thickness 188

Diameter	From	To
8 inches	0 feet	260 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3/32
From 230 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface 40
Flow G.P.M.
Water temperature 115 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gordon McKay
Address 690 Starlight Cr
Nevada contractor's license number 14170
Nevada driller's license number 1089
Signed Gordon McKay
Date 4-17-80

USE ADDITIONAL SHEETS IF NECESSARY

5471