WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

Dons. 140 ft. [illegible] 3

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 21036
Permit No.
Basin

1. OWNER Don Bartholomew ADDRESS 2812 Squires & Stephanie RTS Box 575 Minden 8949

2. LOCATION ¼ ¼ Sec. 28 T. 14 N/S R. 20 E. Douglass Coun
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
4 3/4 Perforated Casing				
12" Hole 52 FT.				
Sand & Clay To 40 FT.				
Sand & Water 90				
Sand Gravel & Water 97				
Sand Gravel		97	125	
Sand & Gravel Clay		125	140	

Date started Aug 4, 1979
Date completed Aug 10, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3400			

BAILER TEST
G.P.M. 15 Draw down 15 feet 8 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" & 8 inches Total depth 140 fe
Casing record 140
Weight per foot Thickness 3/16

Diameter	From	To
inches	feet	fe
inches	feet	fe
inches	feet	fe
inches	feet	fe
inches	feet	fe
inches	feet	fe

Surface seal: Yes ☐ No ☐ Type
Depth of seal 52 fe
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to fe

Perforations:
Type perforation Factory. 40 ft.
Size perforation 3/32
From 100 feet to 140 fe
From feet to fe
From feet to fe
From feet to fe
From feet to fe

9. WATER LEVEL
Static water level 45 Feet below land surface 95
Flow NO G.P.M. 15
Water temperature 54 °F. Quality Good.

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true t the best of my knowledge.

Name
Address
Nevada contractor's license number
Nevada driller's license number 1016
Signed
Date

USE ADDITIONAL SHEETS IF NECESSARY

5471