WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 21059
Permit No. 30614
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER EL CAPITAN CLUB ESTATES ADDRESS P.O. 1187 HAWTHORNE, NV. 89415

2. LOCATION NW ¼ SW ¼ Sec. 33 T. 8 N/S R. 30 E. Mineral County
PERMIT NO. 30614

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
hard dg w/boulders		0	85	85
hard dg		85	138	53
granite boulders		138	145	7
hard dg		145	159	14
hard dg w/boulders		159	294	135
hard dg w/fractured rock		294	462	168
hard dg w/fractured rock & clay streaks		462	491	29
hard rock		491	497	6
hard rock w/clay streaks		497	565	68
fractured granite w/clay streaks	x	565	797	232
hard dg	x	797	970	173
fractured rock w/clay streaks	x	970	1000	30

Date started 2/14, 19 80
Date completed 5/2, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1400-2000	Developing		76
1700	600	600	6
1800	700	610	6
1900	800	625	12

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 26"/18 5/8" inches Total depth 60'/1000 feet
Casing record
Weight per foot 33.38 Thickness .250

Diameter	From	To
12 3/4 od inches	0 feet	1000 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 55' w/5" gravel feed pipe feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 1000 feet

Perforations:
Type perforation milled
Size perforation 3" x 1/8" d st
From 590 feet to 1000 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 585 Feet below land surface
Flow ..... G.P.M.
Water temperature 210 °F. Quality Being Tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS. DRILLING, INC.
Address 1500 E.RANGER RD.
Nevada contractor's license number 7462A
Nevada driller's license number 615
Signed W. L. Sage
Date 5/5/80

USE ADDITIONAL SHEETS IF NECESSARY

5471