WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

Harry

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 21070
Permit No. 39831
Basin

Hole # 6 (SEA DEVELOP)

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Pahrump Development Co. ADDRESS [illegible] Pahrump Nev.

2. LOCATION SW ¼ SW ¼ Sec. 36 T. 20 N/S R. 2 E. Nye County
PERMIT NO. 39831

3. TYPE OF WORK
test New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	9	
Sandy clay		9	58	
Clay		58	75	
Sand	95	75	81	
Sandy clay		81	129	
Sand and gravel		129	245	
Sand with clay				
[illegible]		245	310	
Sand		310	376	

Date started 3/12, 1980
Date completed 3/15, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6¼ inches Total depth 376 feet
Casing record 6 5/8 x 5 conductor
Weight per foot 13 Thickness .156

Diameter	From	To
6 5/8 I.D. inches	0 feet	67 feet
inches	feet	feet
inches	surface feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☑ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 25 Feet below land surface
Flow G.P.M. 200
Water temperature 80 ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams
Address 22 South Pattison, Las Vegas
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul Williams
Date 3/16/80

USE ADDITIONAL SHEETS IF NECESSARY

5471