



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER TOM MUELLER - Justice Power ADDRESS SPARKS, NEVADA 89431
615 Capistrano Dr.
 2. LOCATION NE 1/4, SE 1/4 Sec. XXX18 T. 21 N/S R. XE21 E WASHOE County
 PERMIT NO. 070-368-59

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Basalt		0	10	10'
blue gray granite		10'	50'	40'
blue gray granite		50'	200'	150'
blue gray granite		200'	350'	150'
blue gray granite, fractures		350'	550'	200'
blue gray granite		550'	650'	100'
blue gray granite, fractures		650'	800'	150'
brown granite		800'	830'	30'
brown granite, some factures		830'	880'	50'
fractures some water		880'	930'	50'
brown granite, fractures				
with water		930'	955'	25'

8. WELL CONSTRUCTION
 Diameter hole 6-5/8 inches Total depth 955 feet
 Casing record
 Weight per foot _____ Thickness _____

Diameter	From	To
<u>6-5/8</u> inches	<u>0</u> feet	<u>700</u> feet
<u>5</u> inches	<u>655</u> feet	<u>955</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation factory sawed slots
 Size perforation 3/32
 From 800 feet to 955 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 650 Feet below land surface
 Flow 10 G.P.M.
 Water temperature _____ ° F. Quality _____

Date started 4-9-80, 19_____
 Date completed 5-3-80, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name VALLEY PUMP COMPANY
 Address P.O. BOX 624, SPARKS, NEV. 89431
 Nevada contractor's license number 6045
 Nevada driller's license number 1044
 Signed Matthew G. Kearney
 Date 5-9-80