

OFFICE USE ONLY  
 Log No. 21087  
 Permit No. 35074  
 Basin I

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER GAMBONI CONSTRUCTION ADDRESS 765 E. Greg St. Sparks, Nev.

2. LOCATION  $\frac{1}{4}$   $\frac{1}{4}$  Sec. 7 T. 17 N/S R. 20 E. Washoe County  
 PERMIT NO. 35074

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input checked="" type="checkbox"/> Stock <input type="checkbox"/>	Other <input checked="" type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Coarse sand, gravel with boulders		0	6'	6'
gravel, boulders		6'	20'	14'
boulders, gravel		20'	50'	30'
coarse sand, clay, gravel, some boulders		50'	88'	38'
coarse sand and water bearing gravel, water		88'	120'	32'
Set pump at 84'				

8. WELL CONSTRUCTION

Diameter hole 8-5/8 inches Total depth 120 feet  
 Casing record.....  
 Weight per foot..... Thickness.....

Diameter	From	To
<u>8-5/8</u> inches	<u>0</u> feet	<u>120</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes  No  Type cement  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 120 feet

Perforations:  
 Type perforation factory sawed slots  
 Size perforation 3/32  
 From 60 feet to 120 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

9. WATER LEVEL

Static water level 52' Feet below land surface.....  
 Flow 100 G.P.M.....  
 Water temperature..... ° F. Quality.....

Date started 5-8-80, 19.....  
 Date completed 5-10-80, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>50</u>	<u>58'</u>	<u>4 hrs.</u>
	<u>105</u>	<u>63'</u>	<u>20 hrs.</u>

BAILER TEST

G.P.M. .... Draw down..... feet ..... hours  
 G.P.M. .... Draw down..... feet ..... hours  
 G.P.M. .... Draw down..... feet ..... hours

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VALLEY PUMP COMPANY  
 Address P.O. BOX 624, SPARKS, NEV. 89431  
 Nevada contractor's license number 6045  
 Nevada driller's license number 1044  
 Signed Matthew Kearney  
 Date 5-14-80