

**WELL DRILLERS REPORT**

Please complete this form in its entirety

50831

1. OWNER City of Yerington ADDRESS.....  
 Well #3

2. LOCATION NE 1/4 SW 1/4 Sec. 14 T. 13 N. R. 25 E. Lyon County.....  
 PERMIT NO. 35974

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input checked="" type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Top Soil		0	13	
coarse gravel		13	16	
Blue clay		16	18	
Sand & gravel 3/4" plus		18	26	
Coarse sand		26	31	
Fine sand w/clay mix		31	39	
Sand and gravel		39	55	
Brown clay		55	60	
Blue clay w/some sand		60	70	
Brown clay		70	74	
Sand and gravel		74	77	
Brown clay		77	88	
Sand and gravel		88	110	
Sand & gravel w/some clay mixed		110	145	
Sand and gravel		145	156	
Gravel w/some clay		156	166	
Gravel		166	170	
Gravel w/some clay		170	175	
Clay		175	176	
Gravel w/some clay		176	185	
Sand and gravel		185	207	
Gravel w/some clay		207	212	
Brown clay		212	222	
Coarse sand & gravel		222	314	
2"-3" rock				

8. WELL CONSTRUCTION

Diameter hole 24 inches Total depth 312 feet  
 Casing record.....  
 Weight per foot..... Thickness 1/4  
 Diameter 16" From +2 To 314  
 inches feet feet  
 Surface seal: Yes  No  Type pipe & cement  
 Depth of seal 97 feet  
 Gravel packed: Yes  No   
 Gravel packed from 0 feet to 312 feet

Perforations:  
 Type perforation Full flo  
 Size perforation 3/32  
 From 112 feet to 312 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

Date started May 5, 1980  
 Date completed May 16, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M..... Draw down.....feet .....hours  
 G.P.M..... Draw down.....feet .....hours  
 G.P.M..... Draw down.....feet .....hours

9. WATER LEVEL

Static water level.....Feet below land surface.....  
 Flow.....G.P.M.....  
 Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name The Water Development Corp.  
 Address P.O. Box 888, Woodland, Ca. 956  
 Nevada contractor's license number 12852  
 Nevada driller's license number 793  
 Signed [Signature]  
 Date 5/17/80