WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 21100
Permit No.
Basin

1. OWNER Paul Grobbin ADDRESS Lot 526 Adobe Rd, Virginia Hilands

2. LOCATION NW ¼ NW ¼ Sec. 33 T. 17 N N/S R. 21 E E Story County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN. TOPSAND		0	1	
YELLOW CLAY		1	37	
BLUE CLAY		37	52	
GRAY CLAY W/SAND STRINGERS +08'	X	52	97+	

Date started 5-3- , 1980
Date completed 5-4 , 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	Blew at 200# for 46 min to clean + develop		
	approx 12 gpm		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4 to 50' 8 3/4 to TD. inches Total depth 97 feet
Casing record 6 5/8 OD
Weight per foot Thickness .156

Diameter	From	To
6 5/8 OD inches	+1 feet	97 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 97 feet

Perforations:
Type perforation FACTORY
Size perforation 1/8 x 3
From feet to feet
From 77 feet to 97 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 30 Feet below land surface
Flow G.P.M. 12
Water temperature cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service
Address 2255 GLENDALE
Nevada contractor's license number
Nevada driller's license number 1037
Signed Kevin Smith
Date 5-5-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627