WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 21146
Permit No.
Basin

1. OWNER Louis - Dringoli ADDRESS Rt #1 359 B Fernley

2. LOCATION NE ¼ SE ¼ Sec. 23 T. 20 N/S R. 25 E. Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil Clay		0	14	14
3" + 2" Rock		14	16	2
¾" + ¼ Gravel		16	34	18
Hard Dry Cracked Clay		34	45	11
Sand		45	54	9
Sand Gravel		54	65	11
Sand Stone	✓	65	66	1
Sand & Gravel	✓	66	85	19
Soft Rock		85	—	—
Well Cased To 83' with 2 feet of Hole in Soft Rock				

Date started April 28, 19 80
Date completed May 7, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Well Air Jetted for 4 hrs			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 85 feet
Casing record
Weight per foot Thickness

Diameter	From	To
8 5/8 inches	01 feet	feet
inches	feet	83 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal Surface feet
Gravel packed: Yes ☐ No ☒
Gravel packed from — feet to — feet

Perforations:
Type perforation Torch Cut
Size perforation 1/8
From 76 feet to 83 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface 53
Flow 24 G.P.M. 25
Water temperature Cold °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul N. Pflimlin
Address 7007 Curry Rd.
Nevada contractor's license number
Nevada driller's license number 928
Signed Paul N. Pflimlin
Date May 7, 1980

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1980 JUN 4 AM 9 15