

Log No. 21198
 Permit No. _____
 Basin. _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Robert Rusk ADDRESS 1338 Jones St. Reno, Nevada
 Job Location 4205 Old 395N Carson City, Nevada

2. LOCATION SW 1/4 1/4 Sec. 3 T. 16 N. 19 E. Washoe County
 PERMIT NO. _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0'	4'	4'
Surface Water at	4'			
Gray Sand		4'	29'	25'
Surface Water	17'			
Gray Clay & Gravel		29'	51'	22'
DG		51'	72'	21'
Clay		72'	75'	3'
Sand & DG		75'	92'	17'
Clay		92'	93'	1'
DG		93'	106'	13'
Rock & Gravel		106'	110'	4'
Sand & Gravel		110'	120'	10'
Granite		120'	124'	4'
Sand & Gravel		124'	135'	11'
Clay		135'	140'	5'
Clay & DG		140'	150'	10'
DG & Gravel		150'	173'	23'
Gray Clay		173'	175'	2'
Rock		175'	180'	5'
DG & Clay		180'	184'	4'
DG		184'	200'	6'
Gray Clay		200'	205'	5'

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 205 feet
 Casing record _____
 Weight per foot _____ Thickness _____

Diameter	From	To
<u>8</u> inches	<u>±1</u> feet	<u>205</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Factory
 Size perforation 3/32 2"
 From 175 feet to 205 feet
 From _____ feet to _____ feet

Date started April 10, 1980
 Date completed May, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1 hp</u>	<u>15</u>	<u>60</u>	<u>48</u>

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 30 Feet below land surface
 Flow 17 G.P.M.
 Water temperature Cold ° F. Quality Good (Iron)

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Russell C. Kabisch
 Address 2270 E. Lake Blvd.
Carson City, Nevada 89701
 Nevada contractor's license number 14170
McKay Drilling, Inc.
 Nevada driller's license number 867
 Signed Russell C. Kabisch
 Date May 26, 1980