WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 21242
Permit No. 30195
Basin

1. OWNER Louis Van Vliet ADDRESS Gardnerville, Nev
Verdi Ave · Dairy ·

2. LOCATION SW ¼ NE ¼ Sec. 18 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. 30195

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt		0	12	12
Boulders Cobble Stones		12	50	38
Cobble stone Coarse gravel		50	110	60
Hard packed gravel		110	140	30
Coarse gravel some boulders — cobbles		140	150	40
gravel some silt —		180	215	35 5
Water all the way —				
				215

Date started May 1, 1980
Date completed May 15, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 100 Draw down 0 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 215 feet
Casing record
Weight per foot 21 Thickness 250

Diameter	From	To
inches	feet	feet
12" 10 inches	0 feet	215 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 + feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 75 feet

Perforations:
Type perforation 1/8 x 3 Factory
Size perforation 1/8 x 3
From 110 feet to 215 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 0 Feet below land surface
Flow G.P.M. 30
Water temperature 54 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Austin W Graham
Address Gardnerville Nev.
Nevada contractor's license number 12953
Nevada driller's license number 751
Signed A W Graham
Date 5-16-1980

USE ADDITIONAL SHEETS IF NECESSARY

O-627