WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 21259
Permit No. 45633
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Dennis & Linda Wells ADDRESS 4550 Flanigan Star Rt Flanigan, Nevada 89510

2. LOCATION FRN ½ ¼ SE ¼ ¼ Sec. 22 T. 27 N N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Sand & Gravel		5	32	27
Brown SANDY CLAY		32	40	8
Course Sand & Gravel	28	40	68	28
Hard Pan Clay		68	90	22
Sand & Gravel	28	90	118	28
Light Blue Clay		118	150	32
Gravel	~~[illegible]~~	150	199	49

Date started June 4, 1980
Date completed June 10, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST Air lifted
G.P.M. 50 Draw down 7 feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 199 feet
Casing record 8 in
Weight per foot Thickness 188

Diameter	From	To
plain 8 inches	0 feet	70 feet
perf 8 inches	70 feet	199 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type
Depth of seal 45 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 45 feet to 199 feet

Perforations:
Type perforation Self perf
Size perforation
From 70 feet to 199 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 42 Feet below land surface
Flow G.P.M. 50
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gary Lee Lope
Address Flanigan Star Rt Flanigan Nev
Nevada contractor's license number
Nevada driller's license number 1155
Signed Gary Lope
Date 6/12/80

USE ADDITIONAL SHEETS IF NECESSARY

O-627