

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER William Blain ADDRESS Box 353 Dayton, NV 89403

2. LOCATION 1/4 Sec. 29 T. 17 N/S R. 25 E. Lyon County  
 PERMIT NO. Riverside #2 Lot 58 Canabow Pass Silver Springs

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	17	17
CLAY		17	38	21
SAND & GRAVEL	65	38	75	37
CLAY		75	111	36
SAND & GRAVEL	111	111	132	21
CLAY & SAND		132	134	2

8. WELL CONSTRUCTION  
 Diameter 8 1/2 inches Total depth 134 feet  
 Casing record 8 5/8  
 Weight per foot 16.9 Thickness 18.8  
 Diameter From To  
8 inches 0 feet 134 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Free flow  
 Size perforation 5 x 3/32  
 From 111 feet to 131 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6/23/80, 19\_\_\_\_  
 Date completed 6/27/80, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 20 Draw down 6 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 69 Feet below land surface  
 Flow 1.0 G.P.M.  
 Water temperature 60.5 Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W. M. Blain  
 Address Box 353 Dayton, NV  
 Nevada contractor's license number 10950  
 Nevada driller's license number 1156  
 Signed Walter Wilkins  
 Date 6/30/80