WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 21271
Permit No.
Basin

1. OWNER Clifford Williams ADDRESS 3822 Walker View Rd. Wellington, Nev. 89444

2. LOCATION SW/4 SE 1/4 Sec. 11 T. 10 N/S R. 22 E. Douglas County
PERMIT NO. Topaz Ranch Estates Lot 20 Unit 1

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Yellow clay and rock alluvial	No	0	175	175
Small rock	Yes	175	185	10
Yellow clay and rock alluvial	No	185	290	105
Small rock	Yes	290	320	30
Bedrock	Yes	320	360	40

Date started 5-29-, 1980
Date completed 6-16-, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 25 Draw down 80 feet 5 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 360 feet
Casing record 320
Weight per foot Thickness 147

Diameter	From	To
8 inches	0 feet	360 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations: * Torch cut
Type perforation ~~* *~~ Factory
Size perforation
* From 303 feet to 320 feet
* From 282 feet to 303 feet
* From 268 feet to 282 feet
From 238 feet to 268 feet
From Cut with perforator feet

9. WATER LEVEL
Static water level 184 Feet below land surface 184
Flow G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Edmund Miller Drilling Co.
Address Box 92, Smith, Nev. 89430
Nevada contractor's license number 12272
Nevada driller's license number 718
Signed Edmund Miller
Date 6-30-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627