

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER RENO RENDING ADDRESS 1705 N. Wells Ave. Reno, NV

2. LOCATION SW 1/4 SE 1/4 Sec 9 T 35 N/S R 56 E Elko County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & gravel		0	40	40
Gravel w/ scarp	scarp	40	42	2
Clay		42	70	28
Gravel	20 gpm	70	122	52
Clay w/ streaks gravel	132 gpm	122	131	9
T.D. 131				

8. WELL CONSTRUCTION
 Diameter hole 10.8 inches Total depth 131 feet
 Casing record 132 x 6.75
 Weight per foot 12.92 Thickness 1.88

Diameter	From	To
inches	feet	feet

 Surface seal: Yes No Type Packland Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 131 feet
 Perforations:
 Type perforation Mill cut
 Size perforation 1/8" x 3" x 12/ft.
 From 80 feet to 120 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 62 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality Good

Date started 5/29, 1980
 Date completed 6/19, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 32 Draw down 40 feet 4 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thomas R. Muth Muth Drilling Co.
203 Pine Street
 Address Elko, Nevada 89801
 Nevada contractor's license number 10819
 Nevada driller's license number 1175
 Signed James Y. Muth 632
 Date 7/22/80