WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 21376
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Jess Sustacha ADDRESS Lamoille, Nevada

2. LOCATION NE ¼ NE ¼ Sec. 31 T. 35N N/S R. 63 E. Elko County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☑

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Bi

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	5	
clay (Damp)		5	15	
Gravel	X	15	25	
mixed gravel & clay	↑	25		
(Tight)			38	
Hard sandstone		38	83	
Sand & clay		83	100	
sandstone		100	110	
clean gravel		110	120	
sandstone		120	165	
clean gravel		165	180	
sandstone thin clay		180	208	
Hard sandstone	↓	208	260	

Date started 8/14, 1980
Date completed 8/21, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	20	27	1

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 260 feet
Casing record
Weight per foot .250 Thickness .250

Diameter	From	To
6 inches	+1 feet	38 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☑ Type
Depth of seal Concrete pad feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 4" feet to 260 feet

Perforations:
Type perforation Factory milled
Size perforation 1/8 x 3"
From 18 feet to 28 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 18 Feet below land surface 18
Flow G.P.M.
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.D. Reynolds
Address Wells, Nevada
Nevada contractor's license number 014410
Nevada driller's license number P16
Signed [signature]
Date 7/28/80

USE ADDITIONAL SHEETS IF NECESSARY

O-627