

Log No. 21398

Permit No.

Basin.....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Mr Callahan ADDRESS Emeralda - White Pine New Washoe

2. LOCATION 1/4 1/4 Sec. 6 T. 16 N/S R. 20 E Washoe County
 PERMIT NO.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Decomposed</u>		<u>1</u>	<u>20</u>	<u>20</u>
<u>1st water</u>		<u>20</u>	<u>25</u>	<u>5</u>
<u>sand-clay</u>		<u>25</u>	<u>50</u>	<u>25</u>
<u>sand</u>		<u>50</u>	<u>75</u>	<u>25</u>
<u>clay-sand</u>		<u>75</u>	<u>80</u>	<u>5</u>
<u>sand</u>		<u>80</u>	<u>90</u>	<u>10</u>
<u>clay</u>		<u>90</u>	<u>100</u>	<u>10</u>

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 100 feet
 Casing record.....
 Weight per foot..... Thickness .188

Diameter	From	To
<u>6</u> inches	<u>1</u> feet	<u>100</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet

Perforations:
 Type perforation torch
 Size perforation.....
 From 95 feet to 55 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Date started 3-10- 1980
 Date completed 3-20 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level..... Feet below land surface
 Flow..... G.P.M.
 Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Marcin Klubbing
 Address 4340 Hwy 50 E
 Nevada contractor's license number 7985
 Nevada driller's license number 707
 Signed Anthony Marcin
 Date 3-21-80