WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 21426
Permit No. 40527
Basin

1. OWNER City of Sparks ADDRESS 431 Prater Way Sparks Nev. 89431

2. LOCATION SE ¼ S.E. ¼ Sec. 3 T. 19 N/S R 20 E. Washoe County
PERMIT NO. Waiver # W-036

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & gravel fill		0	4	
Topsoil		4	7	
sandy Clay		7	51	
sand & gravel		51	94	
sand with Clay		94	123	
sand & gravel	140	123	144	

Date started 6/20, 1980
Date completed 6/22, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 144 feet
Casing record
Weight per foot 17 Thickness .188

Diameter	From	To
8 3/8 O.D. inches	0 feet	144 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Sand & Cement
Depth of seal 70 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 100 feet to 144 feet

Perforations:
Type perforation factory sawed
Size perforation 3/32 x 2½"
From 124 feet to 144 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 24 Feet below land surface
Flow ..... G.P.M. 80
Water temperature cold ° F. Quality Cloudy

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams
Address 22 S. Patterson Sparks
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul Williams
Date 6/20/80

USE ADDITIONAL SHEETS IF NECESSARY

O-627