

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Sunedco ADDRESS P. O. Box 1270
Fallon, Nevada 89406

2. LOCATION 1/4 1/4 Sec. 21 T. 24 N. R. 37 E. Churchill County
 PERMIT NO. 918701

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input checked="" type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Gravel		0	3	3
Clay		3	25	22
Water Bearing Gravel	X	25	30	5
Clay		30	99	69
Water Bearing Gravel	X	99	100	1
Clay		100	178	78
Water Sand	X	178	180	2
Clay		180	215	35
Water Bearing Gravel	X	215	220	5
Clay		220	265	45

8. WELL CONSTRUCTION

Diameter hole 9-7/8 inches Total depth 265 feet
 Casing record.....
 Weight per foot 12.92 Thickness 1.88

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>265</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 265 feet

Perforations:
 Type perforation Factory
 Size perforation 1/8" Slots 6 Rows
 From 115 feet to 265 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Date started July 3, 1980
 Date completed July 5, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Test **WATER TEST**

G.P.M. <u>60</u>	Draw down <u>95</u> feet	<u>1/2</u> hours
G.P.M. <u>110</u>	Draw down <u>160</u> feet	<u>1/2</u> hours
G.P.M.	Draw down..... feet hours

9. WATER LEVEL

Static water level 20 Feet below land surface 20
 Flow..... G.P.M.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jerrold D. Christiansen
 Address 557 Ely Ave., Ely, Nevada 89301
 Nevada contractor's license number 14790
 Nevada driller's license number 641
 Signed Jerrold D. Christiansen
 Date August 4, 1980