WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 21436
Permit No.
Basin.

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Tom Pratt ADDRESS 6105 Whiskey Springs Pleasant Valley
Double P Partnership
Parcel # 42-1-1
2. LOCATION NW ¼ NW ¼ Sec. 4 T. 22 N/S R. 21 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top soil		0	4"	
Clay sand		4	50'	
Clay with tracing of gravel		50	90	
Clay-Big		90	145	
Sand & gravel		145	166	

Perf log = 7x10

Date started 7/26, 19 80
Date completed 7/28, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 15 Draw down feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. 10" To 60' 8" To 166 WELL CONSTRUCTION
Diameter hole 6 inches Total depth 166 feet
Casing record
Weight per foot Thickness

Diameter	From	To
6 5/8 inches	-2 feet	166 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type 55' Cement
Depth of seal 55' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55' feet to 166 feet

Perforations:
Type perforation factory
Size perforation 1/8 x 3"
From 166' feet to 146 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 Feet below land surface
Flow G.P.M. 15
Water temperature COLD ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service
Address 2255 Glendale Sparks
Nevada contractor's license number 15291
Nevada driller's license number 1033
Signed Ronald F Haney
Date 8/3/80

USE ADDITIONAL SHEETS IF NECESSARY

5471