WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

1st Book

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 21572
Permit No. 36272
Basin 162

1. OWNER Joe Farber ADDRESS

2. LOCATION N.E. ¼ N.W. ¼ Sec. 24 T. 20 S. N/S R. 53 E. Nye Cou
PERMIT NO. Quasi-Municipal Permit No. 36272

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel, cobbles		0	15	15
Gravel, cobbles		15	30	15
Gravel, cobbles		30	45	15
Gravel, cobbles		45	60	15
Gravel, cobbles		60	75	15
Gravel, cobbles		75	90	15
Gravel, cobbles		90	105	15
Gravel, cobbles		105	120	15
Gravel, cobbles		120	135	15
Gravel, cobbles		135	150	15
Gravel, cobbles		150	165	15
Gravel, cobbles		165	180	15
Gravel, cobbles		180	195	15
Gravel, cobbles		195	210	15
Gravel, cobbles		210	225	15
Gravel, cobbles		225	240	15
Gravel, clay strs.		240	255	15
Gravel, clay strs.		255	270	15
Gravel, clay strs.		270	285	15
Gravel, clay strs.		285	300	15
Gravel, clay strs.		300	315	15
Gravel, clay strs.		315	330	15
Gravel, clay strs.		330	345	15
Gravel, clay strs.		345	360	15
Gravel, clay strs.		360	375	15
Gravel, clay strs.		375	390	15
Gravel, clay strs.		390	400	10

Date started 5-30, 1980
Date completed 6-18, 1980

7. WELL TEST DATA

Pump	G.P.M.	Draw Down	After Hours Pump

RECEIVED
AUG 25 1980
Div. of Water Resources
Branch Office—Las Vegas, Nev.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 400 f
Casing record 8 5/8
Weight per foot ..... Thickness 134

Diameter	From	To
8 5/8 inches	400 feet	0 f
inches	feet	f
inches	feet	f
inches	feet	f
inches	feet	f
inches	feet	f

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50'
Gravel packed: Yes ☑ No ☐
Gravel packed from 400 feet to 50 f

Perforations:
Type perforation torch
Size perforation 1/4" by 8"
From 220 feet to 400 f
From ..... feet to ..... f
From ..... feet to ..... f
From ..... feet to ..... f
From ..... feet to ..... f

9. WATER LEVEL
Static water level 156 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true the best of my knowledge.

Name John Floyd
Address P.O. Box 292
Nevada contractor's license number 12344
Nevada driller's license number 588
Signed John Floyd
Date 6-18-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627