WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 21660
Permit No. 44244
Basin 12-189a

I

1. OWNER J. Wayne Gattshell ADDRESS P.O. Box 7282 Reno, Nevada

2. LOCATION Approx. Center SE ¼ NW ¼ Sec. 15 T. 40 N/S R. 69 E. Elko County
PERMIT NO. PH-673-2287 Winecup Ranch

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☑

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	3	
dirty gravel		3	37	
clay & sand		37	56	
coarse gravel		56		
thin clay & sand			65	
soft clay Brown		65	72	
(hard) gravel		72	80	
soft Brown clay		80	96	
loose 1½" - gravel		96	115	
fine gravel		115	—	

Date started 9/24/, 1980
Date completed 9/27/, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20+ Draw down 0 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 112 feet
Casing record
Weight per foot Thickness .219

Diameter	From	To
8 inches	+1 feet	112 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☑ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet
Backfilled with hole cuttings
Perforations:
Type perforation Factory milled
Size perforation
From 95 feet to 112 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 85 Feet below land surface 85
Flow G.P.M.
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R. D. Reynold
Address Wells Nevada
Nevada contractor's license number 014410
Nevada driller's license number 706
Signed [signature]
Date 9/30/80

USE ADDITIONAL SHEETS IF NECESSARY

O-627