WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 21699
Permit No. 31851
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Trandec Development C/O Roy Hibdon, P.E. ADDRESS 1479 South Wells Reno, Nevada 89502

2. LOCATION NE ¼ SW ¼ Sec. 13 T. 19N N/S R. 18 E. Washoe County
PERMIT NO. 31851

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☐ Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐ mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Completion of test hole drilled 6-19-79				

Date started September 8, 19 80
Date completed September 16, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
TESTING IN PROGRESS			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole ~~X 12½~~ 12" inches Total depth 180 feet
Casing record 0-180' x 8 5/8" OD
Weight per foot 16.94 Thickness .188

Diameter	From	To
8 5/8 inches	0 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type grout
Depth of seal 78' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from feet to 180 feet

Perforations:
Type perforation Johnson Screen
Size perforation .060
From 100 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
Address P.O. Box 404 Sparks, Nevada 89431
Nevada contractor's license number 9767
Nevada driller's license number 953
Signed D. Cohen by W. L. McDonald
D. Cohen by W.L. McDonald
Date 16 September, 1980

USE ADDITIONAL SHEETS IF NECESSARY

O 627