WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

#1 Well #33

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 21779
Permit No.
Basin

1. OWNER U.S. Navy ADDRESS Fallon Naval Air Station, Fallon Nv.

2. LOCATION SW ¼ SE ¼ Sec. 7 T. 17 (N) S R. 28 E. Churchill County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand-Fine		0	9	
Brown + Gray clay		9	60	
Black Clay		60	110	
Gray Clay + Coarse Sand-Water		110	170	
Conglomerants of Colored Rock Chips and Sand		170	444	
Fine Sands with Scattered Basalt Rock		444	502	

Date started 10-19, 19 79
Date completed 10-21, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 1/4 inches Total depth 502 feet
Casing record 2" Black T.C.
Weight per foot Thickness

Diameter	From	To
2 inches	0 feet	502 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 502 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation None
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level — Feet below land surface
Flow — G.P.M.
Water temperature 67 °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling + Well Service
Address 2255 Glendale Road
Nevada contractor's license number 15291
Nevada driller's license number 1132
Signed R M Thrall
Date 11-7-79

USE ADDITIONAL SHEETS IF NECESSARY

5471