

OFFICE USE ONLY  
 Log No. 22051  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER CHEVRON RESOURCES CO. ADDRESS 800 S. 3rd St. Reno, NV 89502  
 2. LOCATION NE 1/4 SW 1/4 Sec. 10 T. 33 N. R. 15 E. Lander County  
 PERMIT NO. GNV-218-TA-02

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. # 16 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel		0	160	160
unconsolid clay sand + gravel		160	240	80
gravel		240	320	80
gravel + sand		320	360	40
gravel		360	420	60
gravel sand +		420	470	50
unconsolid clay		470	470	0
grey silt		470	470	0

8. WELL CONSTRUCTION  
 Diameter hole 5 1/4 inches Total depth 475 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness \_\_\_\_\_  

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type CEMENT  
 Depth of seal 10 feet  
 Gravel packed: Yes  No  SACK FILL  
 Gravel packed from 10 feet to 475 feet  
 Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-21-77, 19 77  
 Date completed 6-22-77, 19 77

9. WATER LEVEL  
 Static water level 370 Feet below land surface 370  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature 77 ° F. Quality \_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name William D. Dyer, Jr.  
 Address Carlin, Nev  
 Nevada contractor's license number 8912  
 Nevada driller's license number 853  
 Signed William D. Dyer, Jr.  
 Date 7-21-77

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours