WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22209
Permit No.
Basin

1. OWNER HENRY MATTEI ADDRESS 280 La Salle Hieghts, Mesa Park

2. LOCATION ¼ ¼ Sec. 13 T. 19 N/S R. 18 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	2	2
Sedimentary rock		2	25	23
Sedimentary rock, clay		25	50	25
" "		50	100	50
" "		100	150	50
" "		150	200	50
" "		200	230	30
fractured granite, basalt		230	280	50
fractured granite, some water		280	300	20
fractured granite, water		300	355	55
set pump at 285'				

Date started 9-3-80, 19
Date completed 9-6-80, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6-5/8 inches Total depth 355 feet
Casing record
Weight per foot Thickness 156

Diameter	From	To
6-5/8 inches	0 feet	355 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 355 feet

Perforations:
Type perforation factory sawed slots
Size perforation 3/32
From 285 feet to 355 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 265 Feet below land surface
Flow 10 GPM G.P.M.
Water temperature cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VALLEY PUMP COMPANY
Address P.O. BOX 624, SPARKS, NEV. 89431
Nevada contractor's license number 6045
Nevada driller's license number 1123
Signed [signature]
Date 10-6-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627