WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22211
Permit No.
Basin

in Book

1. OWNER Valley Electric ADDRESS

2. LOCATION SE ¼ SW ¼ Sec. 16 T. 20 S N/S R. 53 E. Nye County
PERMIT NO. 36574

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
br. clay, tan clay		0	14	14
gravel + cali strs.		14	35	21
tan clay		35	40	5
gravel, cali strs.		40	50	10
tan clay		50	60	10
tan clay, hard pan, cali strs.		60	75	15
tan clay		75	90	15
tan clay, br. clay		90	105	15
tan clay		105	120	15
tan, clay, cali strs, T of gravel		120	135	15
tan, clay, cali strs, T of gravel		135	150	15
tan clay, white clay, cali strs, gravel		150	162	12
cemented gravel		162	170	8
tan clay, w/gravel, cali strs.		170	195	15
tan clay, w/gravel, cali strs		195	210	15
" " " "		210	225	15
" " " "		225	240	15
tan clay, w/gravel, cali strs.		240	255	15
tan clay, w/strs. cali, T gravel		255	270	15
" " " " "		270	285	15
" " " " "		285	296	11
cemented gravel		296	298	2
tan clay, w/gravel, cali strs.		298	325	27
cemented gravel		325	327	2
tan + white clay, w/cali strs, gravel strs		327	340	13
cemented gravel		340	347	7
tan, white clay, gravel cali strs.		347	360	13

Date started 10/20/80, 19
Date completed 10/27/80, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
DEC 3 1980
Div. of Water Resources
Branch Office — Las Vegas, Nev.

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 400 feet
Casing record 8 5/8
Weight per foot Thickness 156 10 gauge

Diameter	From	To
8 5/8 inches	0 feet	400 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type concrete
Depth of seal 68 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 400 feet to 68 feet

Perforations:
Type perforation torch
Size perforation 1/8" by 12"
From 480 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 36 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name John Floyd
Address P.O. Box 292
Nevada contractor's license number 12344
Nevada driller's license number 588
Signed John Floyd
Date 10/27/80

USE ADDITIONAL SHEETS IF NECESSARY

O-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22211
Permit No.
Basin

1. OWNER Valley Electric ADDRESS

2. LOCATION SE ¼ SW ¼ Sec. 16 T. 20 S ~~N~~/S R. 53 E Nye County
PERMIT NO. 36574

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
tan clay white clay		360	380	20
gravel + cali stks.				
cemented gravel		380	383	3
tan clay w/cali		383	400	17
gravel stks.				

Date started 10/20/80, 19
Date completed 10/27/80, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED DEC 3 1980 Div. of Water Resources Branch Office — Las Vegas, Nev.

BAILER TEST
G.P.M. N/A Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 400 feet
Casing record 8 5/8
Weight per foot Thickness 156 10 gauge

Diameter	From	To
8 5/8 inches	0 feet	400 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal ~~30~~ 68' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 400 feet to ~~300~~ 68' feet

Perforations:
Type perforation Torch
Size perforation 1/8" by 12"
From 400 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 36' Feet below land surface
Flow G.P.M.
Water temperature °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name John Floyd
Address P.O. Box 292
Nevada contractor's license number 12344
Nevada driller's license number 588
Signed John Floyd
Date 10-27-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627