

Log No. 22383
 Permit No.
 Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Bill Kuperus ADDRESS Carson City, Nev.

2. LOCATION ne 1/4 NW 1/4 Sec. 7 T. 14 N/S R. 20 E. Douglas County
 PERMIT NO.

| | | | | | | | |
|--|--------------------------------------|--|--|-------------------------------------|--------------------------------|----------------------------------|---------------------------------|
| 3. TYPE OF WORK | | | 4. PROPOSED USE | | | 5. TYPE WELL | |
| New Well <input checked="" type="checkbox"/> | Recondition <input type="checkbox"/> | | Domestic <input checked="" type="checkbox"/> | Irrigation <input type="checkbox"/> | Test <input type="checkbox"/> | Cable # <input type="checkbox"/> | Rotary <input type="checkbox"/> |
| Deepen <input type="checkbox"/> | Other <input type="checkbox"/> | | Municipal <input type="checkbox"/> | Industrial <input type="checkbox"/> | Stock <input type="checkbox"/> | Other <input type="checkbox"/> | |

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------|--------------|------|-----|------------|
| Clay & Small Rock | | 0 | 20 | 20 |
| D.G & Clay | | 20 | 120 | 100 |
| Sand | w/s | 120 | 123 | 3 |
| Sand & Clay | | 123 | 150 | 27 |
| Sand | w/s | 150 | 160 | 10 |
| Sand & Clay | | 160 | 163 | 3 |

Well is rocked in bottom from 155' to 163' to prevent sand.

8. WELL CONSTRUCTION

Diameter hole 8 5/8 inches Total depth 163 feet
 Casing record
 Weight per foot Thickness 188

| Diameter | From | To |
|--------------|------------|------------|
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes No Type Cement
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from feet to feet

Perforations:

Type perforation Factory
 Size perforation 1/16
 From 118 feet to 163 feet
 From feet to feet

Date started 1/15/81, 19.....
 Date completed 1/21/81, 19.....

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL

Static water level 120 Feet below land surface
 Flow 15 G.P.M.
 Water temperature ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim House & Son's Drilling
 Address P.O. Box 2192 Carson City, Nev.
 Nevada contractor's license number 12554
 Nevada driller's license number 651
 Signed Steve House
 Date 1/21/81

BAILER TEST

G.P.M. 15 Draw down 30 feet 4 hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours