


WELL DRILLERS REPORT

Please complete this form in its entirety



1. OWNER B.T. REMLEY ADDRESS _____

2. LOCATION 1/4 NW 1/4 Sec. 18 T. 10 N. R. 22 E. DOUGLAS County
 PERMIT NO. PARCEL 2.D

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY BOULDERS		0	65	65
BOULDER		65	70	5
CLAY SAND				
ROCK		70	110	110
BOULDER		110	112	2
CLAY SAND				
ROCK		112	150	38
CLAY SAND				
GRAVEL WATER	160	150	170	20
ROCK		170	175	5
CLAY SAND				
GRAVEL WATER	175	175	190	15

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 190 feet
 Casing record BLACK 0-160
 Weight per foot 16.94 Thickness 1.88

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>50</u> feet
<u>10</u> inches	<u>50</u> feet	<u>190</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CANCELLED
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 190 feet

Perforations:
 Type perforation MACHINE
 Size perforation 3/32
 From 160 feet to 190 feet
 From _____ feet to _____ feet

Date started 12-9, 1980
 Date completed 1-12, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 141 Feet below land surface
 Flow _____ G.P.M.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ACE PUMP SALES & SERVICE
555T Highway 50 E, #5
 Address Carson City, Nev. 89701

Nevada contractor's license number 15429
 Nevada driller's license number 561+203

Signed JAMES W THOMPSON
 Date 1-26-81

BAILER TEST

G.P.M. 25 Draw down 190 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours