WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22468
Permit No. 30261
Basin

1. OWNER KEYSTONE REALTY ADDRESS 551 Keystone Ave Reno, Nev. 89503

2. LOCATION ¼ S ½ ¼ Sec. 30 T. 18 N/S R. 20 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brn clay w/boulders		0	4	4
brn sand brn clay		4	18	14
rock broken Wgranite	bldrs	18	102	84
bl.rock loose volcanic				
rock & sand		102	138	36
white granite med hard		138	162	24
brn sand w/clay		162	258	96
clay layerw/ sand		258	310	52
gray granite	x	310	348	38
brn DG w brn clay		348	365	17
brn DG w/white clay		365	396	31
brn DG hard		396	412	16
brn DG crs med hard	xx	412	431	19
gray granite med hard		431	458	27
blue granite med hard		458	525	67
hard blue granite		525	547	22
water at this depth 20 GPM				

TEST HOLE

Date started 11-22, 19 78
Date completed 11-29, 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 547 feet
Casing record 300 ~~xx~~ ft.
Weight per foot ..... Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 75 ft. feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation none - test hole only
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 225 Feet below land surface
Flow 20 G.P.M. AIR TEST
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC.
Address P. O. Box 12370 Reno, Nev. 89510
Nevada contractor's license number 14043
Nevada driller's license number 471
Signed Wayne Hahman
Date 2-16-81

USE ADDITIONAL SHEETS IF NECESSARY

O-627