WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 22483
Permit No. W-052
Basin

1. OWNER COLLINS, RYDER, & WATKINS ADDRESS 100 NORTH ARLINGTON SUITE 350 RENO, NV 89501

DOUBLE DIAMOND DEVELOPMENT

2. LOCATION SW ¼ SE ¼ Sec. 8 T. 18 N/S R. 20 E. WASHOE County
PERMIT NO. W-052

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE observation
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ~~XXXX~~ | | | | |
| surface soil | | 0 | 5 | 5 |
| alluvium fill | XX | 5 | 300 | 295 |

NOTE: well was fitted with a three foot length of plastic pipe above the ground to avoid flowing

Date started ~~XXXXXXX~~ January 12, 19 81
Date completed January 14, 19 81

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| blowen w/air after cased & cemented | 20 | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 9 7/8 inches Total depth 300 feet
Casing record 2" ID galvanized pipe
Weight per foot 3/65 Thickness

| Diameter | From | To |
|---|---|---|
| 9 7/8 inches | 0 feet | 300 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Haliburton pure cement
Depth of seal 70 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 70 feet to 300 feet

Perforations:
Type perforation torched
Size perforation
From 100 feet to 120 feet
From 140 feet to 160 feet
From 180 feet to 200 feet
From 220 feet to 240 feet
From 260 feet to 280 feet

9. WATER LEVEL
Static water level above Feet below land surface
Flow G.P.M.
Water temperature 58 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING CO., INC.
Address 1500 EAST RANGER ROAD RENO, NV 89506
Nevada contractor's license number 7462A
Nevada driller's license number 615
Signed W. L. Sage
Date JANUARY 31, 1981

USE ADDITIONAL SHEETS IF NECESSARY

5471