WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 22538
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Richard Thomas ADDRESS 1473 Gunary Rd Pflm NV 89048

2. LOCATION E¼ NW¼ NW¼ Sec. 23 T. 15 N/S R. 20 E. C.C. County
PERMIT NO. [illegible] Pahrump Hills - 3rd Tyler Rd

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Rock		0	70	70
Conglomerate Rock		70	135	65
[illegible]	X	135	[illegible]	[illegible]
Conglomerate	X	152	154	2

Date started 12-11-80, 19
Date completed 12-15-80, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 15 Draw down 3 feet 1½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
12" 50' 154'
Diameter hole 12¼ inches Total depth 154' feet
Casing record 8 3/8
Weight per foot 16.9 Thickness .188

Diameter	From	To
8 inches	0 feet	152 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 95 feet to 50 feet

Perforations:
Type perforation Factory
Size perforation 3 x 3/32
From 132 feet to 152 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 130 Feet below land surface
Flow No G.P.M.
Water temperature 70 Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W M Blair
Address Box 353 Dayton NV 89403
Nevada contractor's license number 11955
Nevada driller's license number 1156
Signed J Austin Wilkerson
Date 1/9/81

USE ADDITIONAL SHEETS IF NECESSARY

O-627