WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

CHECKED w/ office ASSESSOR 9/8/88 TKG

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22544
Permit No.
Basin

1. OWNER CLARENCE PRICE ADDRESS 9210 Wigwam Reno, Nevada
CHANGED TO: 92-101-32 9750 N. VA.
location parcel 82-100-20 8995 N. Virginia Reno, Nevada
2. LOCATION SW ¼ NW ¼ Sec 5 8 T. 20 N/S R. 19 E Washoe County
PERMIT NO.

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brn-clay		0	60	60
loose rock w/clay		60	90	30
broken rock	x	90	180	90

Date started 2-26-81 19
Date completed 2-27-81 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 180 feet
Casing record 180 ft
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 50 ft. feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 180 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2¼ x 6 around
From 80 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35 Feet below land surface
Flow 7 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC.
Address P. O. Box 12370 Reno, Nev. 89510
Nevada contractor's license number 14043
Nevada driller's license number (923)
Signed Ed Mendrazon
Date 3-4-81

USE ADDITIONAL SHEETS IF NECESSARY

0-627

OFFICE
STATE ENGINEER

1981 MAR 9 AM 11 53