WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22607
Permit No.
Basin 56

1. OWNER Yomba Shoshone Housing ADDRESS Reese River Valley, Nevada #6

2. LOCATION NE ¼ SW ¼ Sec. 8 T. 14 N/S R. 41 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	1	1
Cobbles & Clay		1	90	89
Sand Gravel & Cobbles.		90	155	65
Medium Coarse Sand	✓	155	180	25
Brown Sticky Clay		180	188	8

Date started March 5, 1981
Date completed March 6, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew 120# air for 1½ HRS. Blowing approx. 20 gpm.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. 10" to 60' WELL CONSTRUCTION
Diameter hole 8½ inches Total depth 188' feet
Casing record
Weight per foot Thickness .156

Diameter	From	To
6⅝ inches	0 feet	188 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 188 feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 4" - 21'
From feet to feet
From 158 feet to 179 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 95 Feet below land surface
Flow G.P.M. 20 GPM
Water temperature COLD ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service
Address 2255 Glendale - Sparks, Nevada
Nevada contractor's license number 15291
Nevada driller's license number 662
Signed Jerry Bergstad
Date March 6, 1981

USE ADDITIONAL SHEETS IF NECESSARY

5471