WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22665
Permit No. 30261
Basin

1. OWNER White Creek Ranch & Cattle Co. ADDRESS 7477 Sandstone Reno Nev.

2. LOCATION NW ¼ SW ¼ Sec. 30 T. 18 N/S R. 20 E. Washoe County
PERMIT NO. 30261

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
hard clay & Boulders		0	140	
Brown DG with clay		140	149	
hard Brown & white granite		149	323	
Fractured granite		323	325	
hard Brown & White granite		325	366	
fractured granite	X	366	369	
hard granite		369	382	
fractured granite		382	398	
med. hard granite		398	501	
fractured granite		501	528	
med. hard granite		528	555	
fractured granite		555	564	
granite large fractures		564	595	
soft granite		595	613	
hard granite		613	707	
Black & white granite		707	727	
large fractures	100	727	730	
med hard granite		730	822	
large fractures	300	822	831	

Date started 3/15, 19 81
Date completed 4/3, 19 81

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 831 feet
Casing record
Weight per foot 36 Thickness 203

Diameter	From	To
10 3/4" inches	0 feet	707 feet
inches	feet	feet
8 5/4 inches	700 feet	831 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type sand & cement
Depth of seal 110 ft. feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation factory saw cut
Size perforation 3/32 x 2½"
From ..... feet to ..... feet
From 700 feet to to 831 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 492 Feet below land surface
Flow ..... G.P.M approx. 450
Water temperature Cool ° F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams & Sons
Address 22 S. Patterson, Sparks
Nevada contractor's license number 14983
Nevada driller's license number 957
Signed Paul Williams
Date 4/5/81

USE ADDITIONAL SHEETS IF NECESSARY

O-627