WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 22734
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Sandy Jeanne Palmer ADDRESS 189 Marton Ave
Lot 14 - Block 5 - Indk Tuna Sub.
Between Sub Springs Road & San Clemente
2. LOCATION SW ¼ ¼ Sec. 19 T. 17 N/S R. 22 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy loam		0	3	3
Clay yellow		3	36	33
Cemented gravel		36	58	22
Clay & pebble stone		58	165	107
Sandstone & gravel	WB	165	185	20
Firm clay & gravel		185	192	7

Date started March 10, 1981
Date completed April 9, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 15 Draw down 0 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 192 feet
Casing record
Weight per foot 17 Thickness 188

Diameter	From	To
8 inches	0 feet	192 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory Cut
Size perforation 3/32 x 4" slots
From 150 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 165 Feet below land surface
Flow G.P.M. 15
Water temperature ° F. Quality Clean

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name James Kovel
Address 107 Rambler Drive Dayton Nevada
Nevada contractor's license number 12554
Nevada driller's license number 846
Signed James Kovel
Date April 13, 1981

USE ADDITIONAL SHEETS IF NECESSARY

O5627