WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 22815
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Norman Hilderbrand ADDRESS 4305 Karen St. Reno

2. LOCATION se ¼ nw ¼ Sec. 30 T. 18N N/S R. 20 E. Washoe County
PERMIT NO. 1523

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	8	8
Sand /water	6	8	20	12
Brown clay / sand &				
gravel mixed	6	20	55	35
sand /water	4	55	72	17
yellow brown clay	4	72	78	6

Date started May 6, 1981
Date completed May 9, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	18	2	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 78 feet
Casing record 78
Weight per foot ..... Thickness .188

Diameter	From	To
8 inches	+1.8 feet	76.2 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 51 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation factory sawed
Size perforation 1/8x4
From 56 feet to 76 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 4 Feet below land surface 4
Flow 18 G.P.M.
Water temperature cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name David E. Ballard McKay Drlg
Address 15000 Perlite Dr. Reno
Nevada contractor's license number 14170
Nevada driller's license number 1274
Signed David E. Ballard
Date May 18, 1981

USE ADDITIONAL SHEETS IF NECESSARY

O-627