PINK—WELL DRILLER'S COPY

(Well not completed - To be completed after test pumping.)

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 22861
Permit No. observation
Basin

1. OWNER B.L.M. ADDRESS Dept. of Interior Washington D.C. (Ertec Western) 3777 Long Beach Blvd Long Beach, Calif. 90807 (213-426-[illegible])

2. LOCATION SE ¼ SE ¼ Sec. 23 T. 13.5 N/S R. 62 E. Clark County

PERMIT NO. TUP N5-81-31 - Page One

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☒ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand & Clay		0	30	30
Sand, clay & gravel		30	40	10
Gravel, clay & lime stone		40	110	70
Altered limestone & chert		110	380	270
Limestone		380	460	80
Cherty limestone		460	571	111
Drill blind		571	628	57

uncontrolled circulation was encountered at 571' water level raised to 352.4'

surface casing 20" diameter set to a depth of 121'-26" open hole to T.D. of 628'-11½"

surface casing was pressure grouted from bottom to top.

This well has not been test pumped as of this date.

When?

Completed this segment 5-6-81

Date started April 13, 1981
Date completed ____, 19__

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED MAY 28 1981 Div. of Water Resources Branch Office—Las Vegas, Nev.

BAILER TEST

G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION

Diameter hole ____ inches Total depth ____ feet
Casing record ____
Weight per foot ____ Thickness ____

Diameter	From	To
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet

Surface seal: Yes ☒ No ☐ Type pressure grout
Depth of seal 121' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation ____
Size perforation ____
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

RECEIVED NOV 18 1981 Div. of Water Resources Branch Office—Las Vegas, Nev.

9. WATER LEVEL

Static water level ~~352.4~~ 1927.6 Feet below land surface 352
Flow ____ G.P.M. ____
Water temperature ____ °F. Quality ____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Irving S. Hulbert
Address 9002 S Hardy Tempe Az
Nevada contractor's license number 889
Nevada driller's license number 1289
Signed Irving S. Hulbert
Date 5-27-81

USE ADDITIONAL SHEETS IF NECESSARY