WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22923
Permit No.
Basin

1. OWNER Lance Matheson ADDRESS General Delivery Lund, Nevada 89317

2. LOCATION NE ¼ SE ¼ Sec. 20 T. 12 N/S R. 62 E. White Pine County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	10	10
Gravel		10	21	11
Clay & Gravel		21	26	5
Clay		26	35	9
Clay & Gravel		35	50	15
Water Bearing Gravel	X	50	58	8
Clay & Gravel		58	84	26
Clay		84	90	6
Clay & Gravel		90	107	17
Water Bearing Gravel	X	107	113	6
Clay		113	120	7

Date started May 27, 19 81
Date completed May 28, 19 81

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Test ~~BAILER TEST~~
G.P.M. 50 Draw down 70 feet ½ hours
G.P.M. 60 Draw down 50 feet ½ hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 120 feet
Casing record
Weight per foot 12.92 Thickness .188

Diameter	From	To
6 inches	0 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 120 feet

Perforations:
Type perforation Factory
Size perforation 1/8" x 3" 6 Rows
From 60 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 Feet below land surface 50
Flow G.P.M.
Water temperature Cold F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don S. Christiansen
Address 557 Ely Ave., Ely, Nevada 89301
Nevada contractor's license number 14790
Nevada driller's license number 705
Signed Don Christiansen
Date May 30, 1981

USE ADDITIONAL SHEETS IF NECESSARY

O-627