

**WELL DRILLERS REPORT**

Please complete this form in its entirety

*Test #1*

1. OWNER Dick Week ADDRESS P.O. Box 5407  
Incline Village, NV 89450

2. LOCATION SE 1/4 SW 1/4 Sec. 1 T. 19 N. R. 26 E. Churchill County  
 PERMIT NO. W-064 42469-42470

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input checked="" type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Yellow silty hardpan		0'	12'	12'
Grey sand fine to coarse with silt some water		12'	22'	10'
Grey to brown sand with silt, very fine & evenly graded		22	92	70'
Blue sand fine with silt water bearing with in-consistant green silt lenses to 4" in thickness		92'	150'	58'
Brown sand fine to coarse (85% fine) water bearing				
TEST HOLE flowing 40 GPM + but controlled				

8. WELL CONSTRUCTION

80-20' x 15" WELL CONSTRUCTION  
 20-130' x 8 1/2" 130-160' x 6" Total depth 160 feet  
 Diameter hole..... inches  
 Casing record..... 21' x 12 3/4" OD casing pressure grouted in place  
 Weight per foot..... Thickness.....

Diameter	From	To
12 3/4" inches		20 feet
..... inches		..... feet
..... inches		..... feet
..... inches		..... feet
..... inches		..... feet
..... inches		..... feet

Surface seal: Yes  No  Type.....  
 Depth of seal..... feet  
 Gravel packed: Yes  No   
 Gravel packed from..... feet to..... feet

Perforations:  
 Type perforation.....  
 Size perforation.....  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

Date started..... April 3, 1981  
 Date completed..... April 9, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.....	Draw down.....feet	.....hours
G.P.M.....	Draw down.....feet	.....hours
G.P.M.....	Draw down.....feet	.....hours

9. WATER LEVEL

Static water level..... Feet below land surface.....  
 Flow..... G.P.M.....  
 Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.  
 Address P.O. Box 404 Sparks, Nevada 89431  
 Nevada contractor's license number 9767  
 Nevada driller's license number 493  
 Signed W.L. McDonald  
 Date 4-14-81