

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER ALAN BOYACK ADDRESS 1117 Sewell Drive  
ELKO, NV.  
 2. LOCATION SW 1/4 NW 1/4 Sec. 8 T. 34 N/R. 55 E. ELKO County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Yellow Clay + Gravel</u>		<u>0</u>	<u>120</u>	<u>120</u>
<u>COARSE GRAVEL + CLAY</u>		<u>120</u>	<u>160</u>	<u>40</u>
<u>Cemented Gravel</u>		<u>160</u>	<u>168</u>	<u>8</u>
<u>Boulders</u>		<u>168</u>	<u>185</u>	<u>17</u>
<u>CLAY + GRAVEL</u>		<u>185</u>	<u>250</u>	<u>65</u>
<u>GRAY CLAY + GRAVEL</u>	<input checked="" type="checkbox"/>	<u>250</u>	<u>370</u>	<u>120</u>
<u>YELLOW CLAY + GRAVEL</u>	<input checked="" type="checkbox"/>	<u>370</u>	<u>400</u>	<u>30</u>

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 400 feet  
 Casing record 400  
 Weight per foot 17# Thickness 1.88  

Diameter	From	To
<u>1.2</u> inches	<u>0</u> feet	<u>50</u> feet
<u>1.0</u> inches	<u>50</u> feet	<u>400</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 400 feet  
 Perforations:  
 Type perforation Factory  
 Size perforation 2" x 1/8"  
 From 340 feet to 400 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5-11, 1981  
 Date completed 5-18, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 293 Feet below land surface  
 Flow NO G.P.M. 18  
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BB Gailley  
 Address ST. RT. B Box 191  
MOUNTAIN HOME, IDA.  
 Nevada contractor's license number 015356  
 Nevada driller's license number 1072  
 Signed BB Gailley  
 Date 5-18-81