WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 23005
Permit No. 43202, 46383
Basin DAYTON V. 8-103

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER c/o Julius Bankowski, Comstock Enterprises ADDRESS Box 718 Carson City, Nev.

2. LOCATION SE ¼ SW ¼ Sec. 20 T. 16 N/S R. 21 E. Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☑ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Small rock and alluvial dirt	No	0	48	48
Solid sandstone strata	No	48	63	15
Sharp gravel and small rock	Yes	63	143	80
Yellow clay	No	143	163	20
Sand and gravel	Yes	163	196	33
Tight rock formation	Yes	196	200	4

Date started 5-20-, 1981
Date completed 5-25-, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 5 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6-bit inches Total depth 200 feet
Casing record 200
Weight per foot Thickness .188

Diameter	From	To
6 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation Saw slot
Size perforation 3/32" x 4"
From 50 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 65 Feet below land surface 75
Flow G.P.M.
Water temperature Cold °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Edmund Miller Drilling Co.
Address Box 92, Smith, Nev. 89430
Nevada contractor's license number 12272
Nevada driller's license number 1226
Signed Mitch Miller
Date 6-22-81

USE ADDITIONAL SHEETS IF NECESSARY

O-627