WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 23034
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Larry Santucci ADDRESS Po Box 11105 South Lake Tahoe Calif

Address of Well 730 Pinto Circle

2. LOCATION ¼ ¼ Sec. 27 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. APN 29-074-016 Rabenstroth Sub Div. Gardnerville Nev.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	40	40
Rock		40	100	60
Gravel		100	117	17

Date started 6/9, 1981
Date completed 6/9, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	18	0	2 Hr.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10" inches Total depth 117 feet
Casing record 6 5/8
Weight per foot 12.89 Thickness 188

Diameter	From	To
6 5/8 inches	0 feet	117 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 60' feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 93 feet to 117 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 39 Feet below land surface 78
Flow 0 G.P.M. 18
Water temperature Cold °F. Quality —

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump + Drilling
Address 20805 Coatu Dr.
Nevada contractor's license number 0122360
Nevada driller's license number 1001
Signed Ivan R. Stroman
Date 6/9/81

USE ADDITIONAL SHEETS IF NECESSARY

O-627