WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 23036
Permit No.
Basin

1. OWNER F.J. Mc Can ADDRESS Box 1425 Gardnerville Nev.
Lot 24 Pinto Circle Rabenstrath Sub Div.
2. LOCATION ¼ ¼ Sec. 24 T. 12 N/S R. 20 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Clay | | 0 | 40 | 40 |
| Sand + Gravel | | 40 | 112 | |

Date started 3/4/81, 19
Date completed 3/4/81, 19

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| Blown | 25 | 0 | 2 Hr |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10" inches Total depth 112 feet
Casing record 6 5/8
Weight per foot 12.89 Thickness .188

| Diameter | | From | | To | |
|---|---|---|---|---|---|
| 6 5/8 | inches | 0 | feet | 112 | feet |
| | inches | | feet | | feet |
| | inches | | feet | | feet |
| | inches | | feet | | feet |
| | inches | | feet | | feet |
| | inches | | feet | | feet |

Surface seal: Yes ☑ No ☐ Type
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 88 feet to 112 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 Feet below land surface 62
Flow 0 G.P.M. 25
Water temperature Cold °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump + Drilling
Address 20805 Cooke Dr
Nevada contractor's license number 0122360
Nevada driller's license number 1001
Signed Don R Strauss
Date 6/5/81

USE ADDITIONAL SHEETS IF NECESSARY

O-627