WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23097
Permit No.
Basin 83

1. OWNER Mr. Cloe ADDRESS Virginia Highlands
21460 SADDLEBACK ROAD APN 3-101-48

2. LOCATION ¼ ¼ Sec. 5 T. 17 N/S R. 21 E. Storey County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
fractured granite		0- n	10	10
decomposed granite		10	20	10
decomposed granite		20	40	20
fractured granite		40	60	20
" "		60	100	40
" "		100	150	50
" "		150	370	220
granite, sand, water		370	400	30
decomposed, granite sand and water		400	425	25

Date started 6-30-81, 19
Date completed ~~XXXXXX~~ 7-8-81, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6-/5-8 inches Total depth 425 feet
Casing record
Weight per foot Thickness

Diameter	From	To
6-/58 inches	0 feet	425 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 425 feet

Perforations:
Type perforation factory sawed slots
Size perforation 3/32
From ~~XXX~~ 365 feet to 425 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 270 Feet below land surface
Flow 40 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VALLEY PUMP COMPANY
Address P.O. Box 624, SPARKS, NEV. 89431
Nevada contractor's license number 6045
Nevada driller's license number 1123
Signed [signature]
Date 7-14-81

USE ADDITIONAL SHEETS IF NECESSARY

O-627