WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23111
Permit No. 36590, 47919-20
Basin

LOT 4
SPAN. SPR #1

1. OWNER Mrs. Joyce E. Swegger & Assoc. (Doug Miller) ADDRESS 1250 Riverside Dr. Reno Nev.

2. LOCATION SW ¼ SW ¼ Sec. 7 T. 20 N/S R. 21 E. Washoe County
PERMIT NO. 36590

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand		0	2	
sandy clay		2	16	
grey clay		16	42	
Valcanic Rock		42	63	
fractured Rock		63	68	
Hard Valcanic Rock		68	75	
fractured Rock		75	84	
Hard Valcanic Rock		84	101	
soft Valcanic Rock		101	124	
hard Rock		124	136	
fractured Val. Rock	✓	136	156	
hard Val. Rock	✓	156	160	
fractured Rock	✓	160	165	

Date started 7/13, 1981
Date completed 7/15/81, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 14 inches Total depth 165 feet
Casing record
Weight per foot 36.71 Thickness .250

Diameter	From	To
14" inches	0 feet	165 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement grout
Depth of seal 56 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 56 feet to 165 feet

Perforations:
Type perforation factory sawed
Size perforation 3/32 x 2½
From ..... feet to ..... feet
From 101 feet to 165 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 27 Feet below land surface
Flow ..... G.P.M. approx. 3000
Water temperature cold ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams & sons
Address 22 So. Patterson, Sparks Nev.
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul E. Williams
Date 7/16/81

USE ADDITIONAL SHEETS IF NECESSARY

O-627