

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Jerry Edelfsen ADDRESS 3615 Churchill Dr.
HEW Washoe City, No.
 2. LOCATION SW 1/4 SW 1/4 Sec 5 T. 16 N. R. 20 E. County
 PERMIT NO.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	5	5
Fine Sand	x	5	20	15
Fine Sand	x	20	60	40
Coarse decomp. granite sand	x	60	100	40
Clay & decomp. granite		100	125	25

8. WELL CONSTRUCTION
 Diameter hole 12 inches Total depth 125 feet
 Casing record.....
 Weight per foot..... Thickness 1.88
 Diameter From To
6 5/8 inches 1 feet 2 feet 110 feet
 inches feet feet
 Surface seal: Yes No Type Pressure grout
 Depth of seal 60 feet
 Gravel packed: Yes No
 Gravel packed from 60 feet to 110 feet
 Perforations:
 Type perforation Fact slot
 Size perforation 3/32
 From 65 feet to 110 feet
 From feet to feet

Date started 6-12-80, 19.....
 Date completed 7-20-81, 19.....

9. WATER LEVEL
 Static water level 30 Feet below land surface
 Flow 0 G.P.M.
 Water temperature Cold ° F. Quality Unknown

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Keith Robertson
Robertson, Eng. & Drilling
 Address 1901 N. Reef, Carson City
 Nevada contractor's license number 11539
 Nevada driller's license number 682
 Signed K. Robertson
 Date 8-3-81

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours