

OFFICE USE ONLY
 Log No. 23184
 Permit No. 48284
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER RAY FERRETTO ADDRESS SPANISH SPRINGS, NEVADA

2. LOCATION NW ~~ASE~~ 2A 1/4 Sec 1 T. 21 N/S R. 20 E. Washoe County
 PERMIT NO. _____

3. TYPE OF WORK		4. PROPOSED USE			5. TYPE WELL	
New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>	Cable <input type="checkbox"/>	Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/>	Other <input type="checkbox"/>	Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand		0	10	10
decomposed granite, gravel		10	50	40
d.g. gravel		50	80	30
fractured granite		80	150	70
fractured granite		150	200	50
fractured granite		200	260	60
fractured granite, water		260	300	40
fractured granite		300	350	50
fractured granite, sand and water		350	400	50

8. WELL CONSTRUCTION

Diameter hole 6-5/8 inches Total depth 400 feet
 Casing record _____
 Weight per foot _____ Thickness _____

Diameter	From	To
<u>6-5/8</u> inches	<u>0</u> feet	<u>400</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 400 feet

Perforations:
 Type perforation factory sawd slots
 Size perforation 3/32
 From 200 feet to 400 feet
 From _____ feet to _____ feet

Date started 8-10-81, 19_____
 Date completed 8-14-81, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 185 Feet below land surface
 Flow 60 G.P.M.
 Water temperature cold ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VALLEY PUMP COMPANY
 Address P.O. BOX 624, SPARKS, NEVADA 89431
 Nevada contractor's license number 6045
 Nevada driller's license number 1123
 Signed [Signature]
 Date 8-19-81