WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23230
Permit No.
Basin

1. OWNER Doyle Hall ADDRESS 6210 S. Jackson Rd. Winnemucca, Nv. 89445

2. LOCATION ¼ ¼ Sec. 12 T. 35N N/S R. 37 E. Humboldt County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil-sandy brown		0	2	2
Gravel brown cemented		2	38	36
Gravely-clay brown		38	51	13
sandy-clay-w-strips		51	98	47
of gravel brown				
Sand & gravel brown		98	110	12
Sand & gravel brown	B.	110	122	12

Date started 8-18-81, 19 81
Date completed 8-20, 19 81

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 11 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 120 feet
Casing record 6 inch
Weight per foot 11 Thickness 156

Diameter	From	To
6 inches	0 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch
Size perforation 4 by 1/8
From 100 feet to 119 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 69 Feet below land surface
Flow 30 G.P.M.
Water temperature 54 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Tom Stites
Address 4410 W. Airview
Nevada contractor's license number 017721
Nevada driller's license number 1190
Signed Tom Stites
Date Sept. 3rd 1981

USE ADDITIONAL SHEETS IF NECESSARY

O-627